




**SERIES TUNNEL LED
ENCLOSURE**

CODE 151345



Datasheet

Electrical characteristics

| | |
|--------------------------|---|
| Insulation Class | I |
| Rated insulation voltage | - |
| Rated operating voltage | - |
| Dissipable Power | - |

| | |
|-----------|-----------------|
| Fuse Type | FUSE 1 X 4A D01 |
|-----------|-----------------|

Mechanical characteristics

| | |
|--------------------------------|--|
| Manufacturing material | Marine aluminium alloy (EN 44300) |
| Treatment type | Fluorozirconic passivation |
| Surface finishing | Non-toxic polyester paint anti UV curing in the oven |
| Color | Grey RAL 7035 (Base), Blue RAL 5012 (Cover) |
| Execution | Wall mounting |
| Hole type | M32 |
| IP Protection degree | IP66 |
| Additional IPdegree protection | - |
| Shock resistance | IK10 according to IEC/EN 62262 |
| Resistance to Glow wire | - |
| Flame rating according UL94 | - |
| Corrosivity category | C4 (ISO 12944) |
| Working Environment Temp. | Min: -25°C ;Max: +50°C |
| Warehousing Temperature | Min: -30°C ;Max: +70°C |

| | |
|---------------------|----------------|
| Dimensions | 252X315X193 mm |
| Internal dimensions | - |
| Net Weight | 0.61 KG |

Reference Standards and Directives

Certification and approval marks IMQ FIRE, CE, UKCA, INTEK FIRE

Directives 2011/65/EU (RoHS), 2012/19/EU (WEEE), 2014/35/EU (LVD)

Reference Standards CEI 64-20:2015, EN 50362:2003, EN 60309 -1:1999, EN 60309-1:1999/A1:2007, EN 60309-1:1999/A1AC:2014, EN 60309 -1:1999/A2:2012, EN 60309-2:1999, EN 60309-2:1999/A1:2007, EN 60309 -2:1999/A2:2012, EN IEC 60331-1:2019, EN IEC 63000:2018, Linee Guida per la progettazione della Sicurezza nelle Gallerie Stradali: Ed.2:2009 par. 3.3.2.1.1 e 3.3.2.1.2, Linee Guida per la progettazione della Sicurezza nelle Gallerie Stradali: Ed.2:2009 par. 3.4.2.1.1 e 3.4.2.1.2

The images are purely indicative. Palazzoli reserves the right to make changes without notice.